



FLOW  
LEVEL  
PRESSURE  
ANALYTICAL  
TEMPERATURE  
INSTRUMENTATION  
PASTEURIZATION CONTROLS

**omd** 800-648-3326  
oliver m. dean, inc. www.omdean.com


## JD - SANITARY DIFFERENTIAL PRESSURE SWITCH

- *Complies with all PMO, CFR and 3A standards*
- *Sensor and range options for standard and high temp (UHT/Aseptic) applications*
- *Options for "split" regenerators and higher pressures now available*
- *Large, bright, LED displays with simple-to-read differential bargraph*
- *Dual 4-20mA retransmission standard*
- *Secondary alarm relay on High Pressure channel is standard*

For over 20 years the Anderson "JD" has been the industry standard for insuring that continuous pasteurizer regenerators operate safely and in compliance with the PMO. Not only is it the simplest way to insure that the booster pump only runs when a safe differential exists across the regenerator,

but it can also improve the operational efficiency of the system. By utilizing one or more of the standard features, the system can be protected against oscillation during start-up, or freeze-up of the cooler. It also can provide a control signal to simplify maintenance of proper system back-pressure. And with the

new high pressure and temperature options you can specify exactly the right unit for your HTST, HHST, or UHT system. For a complete package of failsafe controls, please ask about our AV9900 STLR (AIC5002) and DART reference thermometer (AIC3348).



# JD Specifications

## GENERAL

Power Supply: 115 or 230 VAC (specify),  
50/60 Hz 30W max.consumption

Pressure Ranges: 0-99 psig, 0-199 psig, 0-9.9 BAR,  
0-19.9 BAR

Differential Ranges: 1-15 psid, 5-75 psid, 0.1-1.5 BAR

Sensor Temperature Range: 25-250°F (SY transducer)  
25-275°F (SR transmitter)  
25-350°F (TFP-2 transmitter)  
25-400°F (TFP-3 transmitter)

Pressure Inputs: 0-50 mV (std), 4-20mA (optional)

Relay Capacity: 5 amps at 115 or 230VAC for both  
Differential (K1) and High Pressure  
Alarm (K2)

4-20mA Retrans: Any two of three channels (specify  
when ordering) internally powered at  
15VDC (500 ohms max loop resistance)

Approvals: FDA Milk Safety Branch memorandum of  
compliance with PMO; UL listed

## ENCLOSURE

Material: Aluminum w/Polyurethane paint

Dimensions: 10"H x 8 1/16"W x 3 15/16"D

Weight: 8 1/4 lbs.

## HOW TO ORDER

### Sanitary Differential Pressure Switch



#### CASE & MOUNT

1 Aluminum case  
(surface or panel  
mount)

#### RANGE

070 0-99 psig  
204 0-9.9 BAR  
247 0-199 psig  
465 0-19.9 BAR

#### ENGINEERING UNITS

G psig  
B BAR

#### DIFFERENTIAL

097 1-15 PSID Diff. (Std. for Range 070)  
101 5-75 PSID Diff. (Std. for Range 247)  
205 .1-1.5 BAR Diff. (Std. for Range 204,465)

#### POWER

1 115V 50/60 Hz  
2 230V 50/60 Hz

#### RETRANSMISSION

1 Past. & Diff. - Std. (4-20mA internally powered)  
2 Raw & Pasteurized (4-20mA internally powered)  
3 Raw & Differential (4-20mA internally powered)

#### INPUTS

1 Raw = mV(SY); Past. = mV (SY) standard

2 Raw = 4-20mA internal power (SR/TFP);  
Past. = 4-20mA internal power (SR/TFP)

3 Raw = mV (SY);  
Past. = 4-20mA internal power (SR/TFP)

4 Raw = 4-20mA internal power (SR/TFP);  
Past. = mV (SY)

5 Raw = mV(SY);  
Past. = 4-20mA ext. power (ext. powered retrans signal)

6 Raw = 4-20mA ext. power (ext. powered retrans signal)  
Past. = mV (SY)

7 Raw = 4-20mA ext. power (TFP)  
Past. = 4-20mA ext. power (TFP)

### Sanitary Transducer with Conduit Housing



#### RANGE

070 0-99 psig  
204 0-9.9 BAR  
247 0-199 psig  
465 0-19.9 BAR

#### ENGINEERING UNITS

G psig  
B BAR

#### FITTINGS

004 1 1/2" Tri-Clamp  
005 2" Tri-Clamp  
016 1 1/2" Cherry "I" (male)  
017 2" Cherry "I" (male)  
027 1 1/2" G & H "H" line (male)  
028 2" G & H "H" line (male)  
044 1 1/2" #14 Bevel Seat (w/nut)  
045 2" #14 Bevel Seat (w/nut)  
059 1 1/2" NPT

#### DIAPHRAGM MATERIAL

1 316 "L" Stainless Steel (Standard)  
2 Hastelloy "C"

#### DIAPHRAGM FINISH

1 Standard (R<sub>a</sub> = 25 microinches)

#### CABLE LENGTH

Code	Length	Code	Length
00	No Cable		
05	25'	21	125'
10	50'	22	150'
15	75'	23	175'
20	100'	24	200'

**NOTE: If ordering SY transducer separately,  
include interface card - matched set\*.  
Information provided below:**

CODE	RANGE	CARD NUMBER
070	0-99 psig	56014-E0084
204	0-9.9 BAR	56014-E0086
247	0-199 psig	56014-E0085
465	0-19.9 BAR	56014-E0085

\* Interface cards for SY  
transducers only.

# SANITARY ELECTRONIC PRESSURE TRANSMITTER - (HIGH TEMPERATURE)



- STYLE**
- 2 High Temp (direct mount)
  - 3 High Temp (remote mount)<sup>1</sup>
- SENSOR TYPE**
- 1 psig/BAR (overpressure/signal shift low)
  - 3 psig/BAR (overpressure/signal shift high) - Standard
- UPPER RANGE LIMIT**
- 3 0-99 psig, 0-9.9 BAR, 0-199 psig
  - 4 0-19.9 BAR
- PROCESS CONNECTION**
- |     |                      |     |                            |
|-----|----------------------|-----|----------------------------|
| 004 | 1-1/2" Tri-Clamp     | 017 | 2" CB "I" (male)           |
| 005 | 2" Tri-Clamp         | 027 | 1-1/2" G&H "H" Line (male) |
| 016 | 1-1/2" CB "I" (male) | 028 | 2" G&H "H" Line (male)     |
- DIAPHRAGM MATERIAL**
- 1 316L Stainless Steel (Std.)
  - 2 Hastelloy "C"
- MOUNTING**
- 1 Direct Mount (Style 2)
- Options below apply to Style 3 ONLY*
- |   |          |   |        |
|---|----------|---|--------|
| A | 5' Poly  | L | 5' SS  |
| B | 10' Poly | M | 10' SS |
| C | 15' Poly | N | 15' SS |
| D | 20' Poly | P | 20' SS |
| E | 25' Poly | Q | 25' SS |
- DISPLAY**
- 1 No display - health authority seal
  - 2 psig display - health authority seal
  - 3 BAR display - health authority seal
- RANGES**
- 070 0-99 psig
  - 204 0-9.9 BAR
  - 247 0-199 psig
  - 465 0-19.9 BAR

## Replacement Interface Cards

RANGE	CARD NUMBER
ALL	56014E0088

Use this card if power to sensor is required (standard).


ALL	56014E0087
-----	------------

Use this card if channel to receive an already powered signal (retran input).

*Note: Replacement card needed only if original is damaged. Calibration will not change if replacing sensor.*

<sup>1</sup> Pipe/Wall mount bracket included with remote mount option (Style 3).


## "TYPICAL" SINGLE REGENERATOR SYSTEM SCHEMATIC



### COMMON JD INPUT SETUP

Standard Temp. Processing = JD INPUT CONFIG "1"  
(SY transducers)  
High Temp. Processing = JD INPUT CONFIG "2"  
(TFP transmitters)

# SR - SANITARY ELECTRONIC PRESSURE TRANSMITTER



## Replacement Interface Cards

RANGE	CARD NUMBER
ALL	56014E0088


Use this card if power to sensor is required (standard).

ALL	56014E0087
-----	------------

Use this card if channel to receive an already powered signal (retran input).

*Note: Replacement card needed only if original is damaged. Calibration will not change if replacing sensor.*

## "TYPICAL" SPLIT REGENERATOR SYSTEM SCHEMATIC



### COMMON JD INPUT SETUP

JD1 = INPUT CONFIG "1"  
(SY transducers)  
JD2 = INPUT CONFIG "5"  
(SY transducers and powered 4-20 input)